

MJ255 LUMINAIRE

VIDEO CONFERENCE

Application: Boardroom (20 people) Light Distribution: Uniformity = good

Facial vertical foot-candles: 75

Luminaires: 12 MJ255

Lens: none

Ceiling height: 9'

Suspension: 0 = lay-in gridHorizontal distance: 5-7'

Tilt from vertical: fixed @ 45 degrees

Throw distance: 6-8'

Total power consumption: 1320 Watt

NOTE

If sunlight is allowed into the room during operation, 5600 Kelin color lamps are recommended. Otherwise, 3000 Kelvin color is recommended.

Also, any ambient lighting operated during shooting should be fitted with the same color lamps in order to avoid potential problems with the white balance

setting of the camera.



(C) PL Systems, Inc. 10529 Olympic Drive, Ste. 102 Dallas, TX 75220 (214) 393-5998 fax (214) 393-5999

Title

HOSPITAL BOARDROOM VIDEO LIGHTING

JUNE 8, 2011

LAD: 3.2.26

0.125"= 1'