



▲ MJ155

▲ MJ124

EDUCATION

Application: College board of governors meeting room (21 people seated)

Light Distribution: Uniformity = good

Facial vertical foot-candles: good

Luminaires: 12 MJ155, 12 MJ124

Lens: none

Ceiling height: 9'

Suspension: 0 = lay-in grid

Horizontal distance: 4-6'

Tilt from vertical: fixed @ 45 degrees

Throw distance: 5-7'

Total power consumption: 960 Watts



© PL Systems, Inc.
10529 Olympic Drive, Ste. 102
Dallas, TX 75220
(214) 393-5998
fax (214) 393-5999

Title
COLLEGE BOARD OF GOVERNORS MEETING ROOM

AUG 6, 2010

LAD 3.3.8

scale 0.1"=1'