



GOVERNMENT

Application: City Council Chamber, eleven

seated.

Light distribution: Uniformity = very good Facial Vertical foot-candles: 60 (front),

40-50 (back)

Luminaires: 10 1SL255 and 4 MSL255

Lens: Wide honeycomb on all

Grid / Ceiling height: 15' with a 15 " riser

Suspension: 2' (center of lens to be 11.5' from riser)

Horizontal distance: 10-12'

Tilt from vertical: front light 35 dgr.

back light 55 dgr. Throw distance: 11-15'

Total power consumption: 1540 Watts

NOTE

If sunlight is allowed into the room during operation, 5600 Kelvin color lamps are recommended. Otherwise, 3000 Kelvin color

is recommended.

Also, any ambient lighting operated during use should be fitted with the same color lamps in order to avoid potential problems with the white balance setting of the camera.



© PL Systems, Inc. 10529 Olympic Drive, Ste. 102 Dallas, TX 75220 (214) 393-5998 fax (214) 393-5999 Title

CITY COUNCIL CHAMBERS

Aug. 23, 2011

LAD: 3.1.16

0.187"= 1'